

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF SALT LICK WATER)	
ASSOCIATION, INC., FOR A DEVIATION FROM)	
THE REQUIREMENTS OF 807 KAR 5:066,)	CASE NO. 90-018
SECTION 5(4), REGARDING WATER STORAGE)	

O R D E R

By application received January 29, 1990, Salt Lick Water Association, Inc. ("Salt Lick") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Salt Lick states in its application that its average daily water usage, including unaccounted-for water, is approximately 27,000 gallons, and that it has no water storage facility.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Salt Lick is not in compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).
2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Salt Lick should be given until March 1, 1993 to bring it within compliance of the Commission's water storage requirements.


IT IS THEREFORE ORDERED that:


1. Salt Lick be and it hereby is given until March 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Salt Lick shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 20th day of February, 1990.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director